

SGS

No: 2620/0279-CER

By the product certificate number

Issued to

License holder

Maitian Energy Co., Ltd.

Room A203, Building C, No. 205, Binghai Six Road, New Airport Industry Area, Longwan District, Wenzhou, Zhejiang Province, China.

Manufacturer

Maitian Energy Co., Ltd. Wuxi Branch

No. 11 Lijiang Road, Xinwu District, Wuxi City, Jiangsu Province, China



It is certified that the product:

Type of generator

PV Inverter

Trademark



Models		T4	T5	Т6	Т8	T10	T12	T15	T17	T20
Technical Data	Rated Active Power	4 kW	5 kW	6 kW	8 kW	10 kW	12 kW	15 kW	17 kW	20 kW
	Rated Voltage	400 V								
	Rated Frequency	50 Hz								
	Firmware version	Master DSP: 1.00 Slave DSP: 1.00 ARM: 1.00								
	Number of phases	Three phase (3/N/PE)								
	Isolation transformer	NO NO								

Is in compliance with

Regulation

EN 50549-1: 2019

Requirements for generating plants to be connected in parallel with distribution networks – Part 1: Connection to a LV Distribution Network - Generating Plants up to and including type B.

This certificate just covers PV inverters models certified below above-mentioned references to be installed in PV generating of type plants A to be connected to a LV distribution network.

The above-mentioned generating unit is certified according to the SGS internal procedure PE.T-ECPE-53 based on the requirements of the UNE-EN ISO / IEC 17065

This certificate is valid until: 26th of August 2023. First issued on: 26th of August 2020.

Madrid, 26th August 2020

Daniel Arranz Muñiz Certification Manager



